

Bethany Christan School

Action Level = >15 ug/L

Repeat Sample

Sample Remarks	Collection Date	Sampling Point	Analyzed Date	Result = ug/L	Location	Collection Date	Analyzed Date	Retest Result 1st Draw	2nd Draw 30 Second Draw
589	5/24/2016	Room 115	5/31/2016	4.5	Faucet				
590	5/24/2016	Room 114	5/31/2016	3.2	Faucet				
591	5/24/2016	Room 116	5/31/2016	2.4	Faucet				
592	5/24/2016	Middle School Entrance Left	5/31/2016	<1.0	Cooler				
593	5/24/2016	Room 210	5/31/2016	<1.0	Bubbler				
594	5/24/2016	Room 215	5/31/2016	<1.0	Bubbler				
595	5/24/2016	Room 213	5/31/2016	<1.0	Faucet				
596	5/24/2016	Outside Gym 2nd Left	5/31/2016	<1.0	Cooler				
597	5/24/2016	Outside Room 306	5/31/2016	<1.0	Cooler				
598	5/24/2016	Teachers Lounge Room 311	5/31/2016	1.8	Faucet				
599	5/24/2016	Room 331 Far Left	5/31/2016	8.0	Faucet				
600	5/24/2016	Outside Room 328 B	5/31/2016	3.2	Cooler				
601	5/24/2016	Room 315 A	5/31/2016	<1.0	Faucet				
602	5/24/2016	Room 331 Left #2	5/31/2016	5.6	Faucet				
603	5/24/2016	Room 331 Left #3	5/31/2016	4.6	Faucet				
604	5/24/2016	Room 331 Right #4	5/31/2016	4.4	Faucet				
605	5/24/2016	Room 331 Far Right	5/31/2016	7.8	Faucet				
606	5/24/2016	Outside Café	5/31/2016	1.4	Cooler				
607	5/24/2016	Outside 341	5/31/2016	1.3	Cooler				
608	5/24/2016	Food Prep 341	5/31/2016	3.1	Cooler				
609	5/24/2016	Wash Area 341	5/31/2016	1.3	Cooler				
610	5/24/2016	Room 345	5/31/2016	1.6	Cooler				
611	5/24/2016	Potter Room	6/1/2016	41	Faucet	6/2/2016	6/18/2016	36	3.9
612	5/24/2016	Across 104 B	5/31/2016	<1.0	Bubbler				
613	5/24/2016	Office	5/31/2016	3.8	Faucet				
614	5/24/2016	Concession Stand Hand Wash	5/31/2016	2.4	Faucet				
615	5/24/2016	Main Left	5/31/2016	3.7	Faucet				
616	5/24/2016	Back Side	5/31/2016	<1.0	Bubbler				
625	5/25/2016	In Hall @ Room 321	6/1/2016	7.5	Cooler				
626	5/25/2016	Room 214	6/1/2016	1.4	Faucet				
627	5/25/2016	Room 214 - Ice Machine	6/1/2016	1.3	Ice				
628	5/25/2016	Room 219	6/1/2016	3.0	Source				
629	5/25/2016	Café Kitchen - Ice Machiine	5/31/2016	<1.0	Ice				